



CABLE TECHNOLOGY LABORATORIES, INC.


NEW BRUNSWICK, NJ

**CTL AGING
OF MEDIUM VOLTAGE CABLES**

by


Carlos Katz

Cable Accelerated Aging Test Set-Up



CABLE AGING METHOD

| | |
|-----------------------|--------------------------------|
| Cable Rating | 15 kV |
| Temperature | $30 \pm 5^{\circ}\text{C}$ |
| Water | Outside - Inside |
| Aging Voltage | $2.5 V_o$ |
| Transients | $1.2 \times 40 \text{ :s.}$ |
| Transient Application | $3 \times 120 \text{ kV/week}$ |
| Aging Coils | 210 ft. |
| Individual Samples | 35 ft. |



ARRANGEMENT FOR SIMULTANEOUS APPLICATION OF SURGES AND OPERATING VOLTAGES



AGING EVALUATION

- Coils Removed at Pre-determined Intervals
- Each Coil Divided into 6-35 Foot Long Samples
- AC and Impulse Breakdown Tests at Ambient Temperature
- Characterization Tests:
 - Treeing Analysis
 - Shields Volume Resistivities
 - Insulation Shield Strippability
 - Insulation Moisture Content

15 KV CABLE CONSTRUCTIONS

| | |
|--------------------|-----------------------------------|
| Conductor | 1/0 (19w), Al. |
| Conductor Shield | 15 mils S.C. XLPE |
| Insulation | 175 mils XLPE or TR-XLPE or EP |
| Insulation Shield | 30 mils S.C. XLPE |
| Concentric Neutral | 16 x #14, Cu |
| Jacket | None |

15 KV CABLE AGING TEST MATRIX

| Aging Voltage – kV | | 15 | |
|---|----------------|-----------------|---------|
| Aging Conditions | Aging (Months) | Breakdown Tests | |
| | | AC | Impulse |
| Unaged | 0 | | |
| A) 30°C Water Outside | 24 | | |
| | 48 | | |
| B) 30°C Water Outside & Inside | 18 | | |
| | 42 | | |
| C) 30°C Outside & Inside with Voltage Transients* | 18 | | |
| | 36 | | |

* 120 kV Standard Impulse Voltages (1.2–1.4 x 40–50 μ s.)

AC VOLTAGE BREAKDOWN STRESS

15 kV Cables Aged at 30°C
(all conditions)

| Insulation | Unaged | Aged 48 Months | |
|------------|--------|----------------|-------------|
| | V/mil | V/mil | % of Unaged |
| XLPE | 1300 | 290-380 | 22-29 |
| TR-XLPE | 800 | 860 | 107 |
| EP | 930 | 320-360 | 35-38 |

IMPULSE VOLTAGE BREAKDOWN STRESS

15 kV Cables Aged at 30°C
(all conditions)

| Insulation | Unaged | Aged 48 Months | |
|------------|--------|----------------|-------------|
| | V/mil | V/mil | % of Unaged |
| XLPE | 3280 | 1260-1610 | 38-49 |
| TR-XLPE | 3020 | 1640 | 54 |
| EP | 1650 | 920-1070 | 56-65 |

More Recent Project

**Field and Laboratory
Accelerated Aging of
EP and TR-XLPE
Distribution Cables**

Project Cables

- 5 Commercial EP's
- 1 Commercial TR-XLPE
- 15KV - 175 Mil - 4/0 Cu
- Concentric Neutral
- Unjacketed

Project Goals


- Age Several EP Cables in Field and Laboratory
- Age TR-XLPE as a Control
- Monitor Field Operational Parameters
- Adjust Laboratory to Field Parameters
- Compare Field Aging to Laboratory Aging
- Develop an EP Aging Model

Three Test Sites


- 13.2/7.62 kV Mid-Circuit
- 34.5/19.9 kV URD Development
- 34.5/19.9 kV Laboratory - CTL



Cable Accelerated Aging Test Set-Up



Laboratory Cable Shield Average Monthly Temp. & Ambient Temp. at O&R



Evaluation Tests

- A.C. Breakdown
- Impulse Breakdown
- Cable Characterization
 - Shield Resistivity
 - Moisture Content of Insulation
 - Partial Discharge
 - Dissipation Factor
 - Shield Strippability
 - Water Tree Analysis

Moisture Content of Insulation


Close to Insulation Shield

| Cable Identification | Moisture Content (%) | | | |
|----------------------|----------------------|--|---|---|
| | New Cable | Aged in Laboratory 55 Months at 2.5 V ₀ | Aged in Field 40 Months at 2.5 V ₀ | Aged in Field 48 Months at 1.0 V ₀ |
| EP | 0.09 | 0.15 | 0.13 | 0.13 |
| EP | 0.13 | 0.71 | 0.30 | 0.44 |
| TR-XLPE | 0.04 | 0.58 | 0.25 | 0.41 |
| EP | 0.06 | 0.14 | 0.11 | 0.14 |
| EP | 0.11 | 0.13 | 0.12 | 0.15 |
| EP | 0.10 | 0.17 | 0.16 | 0.20 |


Dissipation Factor

| Cable Identification | 100 Tan δ at 20 kV | | | |
|-----------------------------|---|--|---|---|
| | New Cable | Aged in Lab. 55 Months at 2.5 V_o | Aged in Field 40 Months at 2.5 V_o | Aged in Field 48 Months at 1.0 V_o |
| EP | 0.15 | 0.14 | 0.14 | 0.15 |
| EP | 1.70 | 3.60 | 2.45 | 3.17 |
| TR-XLPE | 0.04 | 0.06 | 0.04 | 0.04 |
| EP | 0.16 | 0.17 | 0.14 | 0.20 |
| EP | 0.15 | 0.15 | 0.15 | 0.16 |
| EP | 0.36 | 0.39 | 0.33 | 0.42 |


A.C. Voltage Breakdown Stress of Cables Aged in Laboratory at 2.5 Vo



A.C. Voltage Breakdown Stress of Cables Aged in Field at 2.5 Vo



A.C. Voltage Breakdown Stress of Cables Aged in Field at Vo



AC Breakdown Strength

Cables Aged in the
Laboratory


VS.

Cables Aged in the Field


A.C. Breakdown Voltage Retention

| | 55 Months in Lab. @ 2.5 V_o | 40 Months in Field @ 2.5 V_o | 48 Months in Field @ 1.0 V_o |
|----------------|--|---|---|
| EP | 76 - 37% | 100 - 49% | 78 - 57% |
| TR-XLPE | 100% | 96% | 100% |


Impulse Voltage Breakdown Stress of Cables Aged in Laboratory at 2.5 Vo



Impulse Voltage Breakdown Stress of Cables Aged in Field at 2.5 Vo



Impulse Voltage Breakdown Stress of Cables Aged in Field at Vo



Impulse Breakdown Strength

Cables Aged in the Laboratory

vs.

Cables Aged in the Field

Impulse Breakdown Voltage Retention

| | 55 Months in Lab. @ 2.5 V_o | 40 Months in Field @ 2.5 V_o | 48 Months in Field @ 1.0 V_o |
|----------------|--|---|---|
| EP | 100 - 69% | 100 - 73% | 100 - 66% |
| TR-XLPE | 58% | 74% | 51% |

STRIPPING STRENGTH AND VOLUME RESISTIVITY

Cables had none or negligible change in:

- Bond strength
- Resistivity of insulation shield
- Resistivity of conductor shield

Conclusions

- Aging medium voltage cables in the laboratory surrounded by 30°C water reproduces field aging of URD cables.
- Laboratory aging in 30°C water results in faster degradation than in the field, because the cables are surrounded continuously by water.

Conclusions (cont.)

- One EP and the TR-XLPE show excellent retainage of ac voltage strength. One EP cable also shows excellent retainage of impulse strength.
- All tested cables indicate negligible changes in stripping strength, shield volume resistivity and partial discharge.

REFERENCES

- » IEEE Standard 1407-1998, “IEEE Trial-Use Guide for Accelerated Aging Tests for Medium-Voltage Extruded Electric Power Cables Using Water-Filled Tanks.
- » EPRI TR-108405-V1 - Project 2713-03, August 1997, “Aging Study of Distribution Cables at Ambient Temperature with Surges”.
- » Katz, C., Seman, G.W., Bernstein, B.S., “Low Temperature Aging of XLPE and EP Insulated Cables with Voltage Transients”, IEEE Trans. on Power Delivery, Vol. PWRD-10, No.1, pp 34-42, January 1995.
- » Katz, C., Fryszczyn, B., Regan, A.M., Banker, W.A., Bernstein, B.S., “Field Monitoring of Parameters and Testing of EP and TR-XLPE Distribution Cables”, IEEE Trans. on Power Delivery, Vol. PWRD-14, No. 2, pp 679-684, July 1999.